

# TRION<sup>®</sup>

## Air Purification Systems



READ AND SAVE THESE INSTRUCTIONS

Comfort*BREEZE*<sup>™</sup>  
CB100/CB100S

Flow-Through Evaporative Humidifier

READ AND SAVE THESE INSTRUCTIONS  
LIRE ET CONSERVER CES INSTRUCTIONS

TABLE OF CONTENTS

1. Warranty Statement ..... 3  
2. Safety Warnings ..... 3  
3. Introduction ..... 4  
    3.1 Basic Operation ..... 4  
    3.2 Specifications Table ..... 4  
    3.3 What's in the Box ..... 4  
4. Installation ..... 4  
    4.1 Clearances ..... 4  
    4.2 Mounting ..... 4  
    4.3 Plumbing ..... 6  
    4.4 Electrical/Wiring ..... 7  
        4.4.1 Wiring CB100 (without water saving controls) ..... 7  
        4.4.2 Wiring CB100S (with ComfortSmart Technology) ..... 7  
5. Operation ..... 7  
    5.1 Preliminary Checkout ..... 7  
    5.2 Starting and Stopping the humidifier ..... 7  
    5.3 End Of Season Decommissioning ..... 8  
6. Maintenance/Troubleshooting ..... 8  
    6.1 Pad Replacement ..... 8  
    6.2 Control Board Faults & Reset ..... 8  
    6.3 Troubleshooting Chart ..... 9  
    6.4 Exploded View/Parts List ..... 10

## 1. Warranty

### Humidifier 5-Year Limited Warranty

This limited warranty covers Trion Residential Type Humidifiers, excluding duct work, wiring and installation. Trion warrants that all new Trion humidifiers are free from defects in material and workmanship under normal, non-commercial use and service. Trion will remedy any covered defects if they appear within 60 months from the date of original installation & subject to the terms and conditions of this Limited 5-Year Warranty stated below:

1. THIS LIMITED 5-YEAR WARRANTY is granted by Trion Customer Service, 101 McNeill Road, Sanford, NC 27330.
2. This warranty shall extend only to any non-commercial owner who has purchased the residential humidifier other than for purposes of resale.
3. All components are covered by this limited warranty except expendable items, such as evaporative pads, media filter pads and nozzles.
4. If, within the warranty period, any Trion residential humidifier unit or component requires service it must be performed by a competent heating and/or air conditioning contractor (preferably the installing contractor). Trion will not pay shipping charges, or labor charges to remove or replace such defective parts or components. If the part or component is found by inspection to contain such defective material and workmanship it will be either repaired or exchanged free of charge at Trion's option, and returned freight collect.
5. In order to obtain the benefits of this limited 5-year warranty, the owner must notify the dealer or distributor of any defect within 30 days of its discovery. If after reasonable time you have not received an adequate response from the dealer or distributor, notify in writing to Trion Customer Service 101 McNeill Road, Sanford, NC 27330, or call 1-800-884-0002 or email customerservice@trioniaq.com Humidifiers which have been installed or become part of real estate cannot be returned. Trion will receive, freight prepaid, only removable parts or components of such defective humidifiers.
6. This limited warranty does not apply to any part or component that is damaged in transit or in handling, has been subject to misuse, neglect or accident; has not been installed, operated and serviced according to Trion's instructions; has been operated beyond the factory rated capacity; or altered in any such way that its performance is affected. There is no warranty due to neglect, alteration or ordinary wear and tear. Trion's liability is limited to replacement of defective parts or components and does not include the payment of the cost of labor charges to remove or replace such defective components or parts.
7. Trion will not be responsible for loss of use of any product; loss of time, inconvenience, or any other indirect, incidental or consequential damages with respect to person or property, whether as a result of breach of warranty, neglect or otherwise. SOME STATES DO NOT ALLOW THE EXCLUSION OR LIMITATION OF INCIDENTAL OR CONSEQUENTIAL DAMAGES, SO THE LIMITATION OR EXCLUSION IN THE PRECEDING SENTENCE MAY NOT APPLY TO YOU.
8. THIS WARRANTY GIVES YOU SPECIFIC RIGHTS, AND YOU MAY ALSO HAVE OTHER RIGHTS WHICH VARY FROM STATE TO STATE.
9. Any warranty by Trion of merchantability, fitness for use or any other warranty (express, implied or statutory), representation or guarantee other than those set forth herein, shall expire at the expiration date of this express limited warranty. SOME STATES DO NOT ALLOW LIMITATIONS ON HOW LONG AN IMPLIED WARRANTY LASTS, SO THE LIMITATION IN THE PRECEDING SENTENCE MAY NOT APPLY TO YOU.
10. Trion reserves the right to make changes in the design and material of its products without incurring any obligation to incorporate such changes in units completed on the effective date of such change.

## 2. Safety & Warnings

### DANGER

#### RISK OF ELECTRIC SHOCK

Before cleaning, servicing, or parts replacement, the unit must be disconnected from all sources of electricity.

### WARNING

Improper installation, adjustment, alteration, service, or maintenance may cause property damage, injury, or death. This appliance must be installed according to these instructions. Read these instructions thoroughly before installing or servicing the unit.

### CAUTION

Read these instructions thoroughly before installing this unit. Check data label and verify electrical specifications agree with those at the point of installation.

### WARNING

Failure to install this unit in a position that is level and plumb may impair the unit's ability to drain if an overflow condition presents itself. Damage to personal property may also result.

### WARNING

Installation in freezing conditions can result in unit failure. Damage to personal property may also result.

## 3. Introduction

The benefits of a properly humidified environment (35-50% Relative Humidity) are many. They include both personal comfort as well as the preservation of furniture, draperies, carpets, wooden floors and cabinets, paintings, pianos, etc. Your home can be more comfortable at a lower temperature (i.e.: 68° F) at 30-40% Relative Humidity (RH) than at 71° to 72° F without controlled humidity. Since every degree of temperature setback represents about 3% of your heating costs, this can possibly represent a significant annual savings. During the heating season, cold air infiltrates the home and must be heated. When heated, this air dries out and greatly increases its capacity to hold more moisture. By using a humidifier, a source of water is provided to satisfy this increased moisture holding capability, rather than having it drawn from our body surface and the surrounding furnishings in the home.

### 3.1 Basic Operation

Your ComfortBREEZE™ flow-through evaporative humidifier operates on the principles of evaporation. Water is introduced to an evaporator pad as warm air is drawn from the duct and circulated through the pad. The warm air evaporates the water and the relative humidity of the air increases. Any excess water is passed to the drain. CB100S units are equipped with a ComfortSmart controller which acts to minimize the amount of water that may flow to the drain by adjusting the total water flow to the humidifier.

Setting the humidistat in the recommended range of 30-40% relative humidity assures automatic humidity control during the heating season. A lower setting may be necessary to prevent condensation on windows. An electronic humidistat is supplied with CB100S units that can automatically adjust the setpoint as the outdoor temperature falls.

No action is needed to turn the humidifier off for the summer months. If desired, simply lower the humidistat setpoint.

### 3.2 "What's In The Box?"

CB100	CB100S	Description
X	X	Humidifier
X		Mech. Humidistat (CB100)
	X	Electronic Humidistat (CB100S)
X		Transformer (CB100 only)
X	X	Parts Bag

### 3.3 Unit Specifications

Type of Unit	Fan-Powered Evaporative
Mounting Location	Warm Air Supply Duct
Capacity (GPD)	20.0 GPD @ 140 °F 16.5 GPD @ 120 °F 10.0 GPD @ 100 °F
Water Supply	20-100 PSI
Voltage(Amps)	120VAC(0.8A)


Unit Dimensions	11.6"W x 10.12"D x 18.12"H
Water Supply Connection	1/4" OD Tubing
Drain Water Connection	1/2" ID Tubing
Duct Opening	13.13"W x 14.25"H
Shipping Weight	17 Lbs.
Operating Weight	13 Lbs.
Approvals	ETL

## 4. Installation


Prior to installing this product:

- Read the instructions carefully and completely to ensure safe operation. Failure to follow the instructions could lead to damage to the product or cause a hazardous condition.
- Check the ratings given on the product to make sure it is suitable for your application.


Remember to select a location that is readily accessible for periodic inspection, cleaning, and service. The following table indicated the minimum allowable installation clearances. The following illustrations show some of the possible installation configurations and where the humidifier should be installed. This model must be installed on the discharge air side of the furnace or heat-pump so that it will operate with the warmest possible air.




Upflow - Side Return



Horizontal Flow



Upflow - Bottom Return



Down-flow

#### 4.1 Recommended Minimum Installation Clearance

Left	3 inches
Right	3 inches
Top	2 inches
Bottom	6 inches
Back	12 inches

### ⚠ CAUTION

This humidifier should be installed by a qualified service person only. Do not connect the unit to the power source until the installation is complete. A thorough checkout of the unit installation should be completed before operating the unit. Failure to follow these directions may void the manufacturer's original warranty.

#### 4.2 Mounting

The ComfortBREEZE CB100 humidifier should be mounted directly to the warm air supply duct of your HVAC system. Since warm air is required for maximum performance, do not mount the humidifier to the return side of the HVAC duct. Certain conditions must be met to ensure proper unit operation. Refer to the following list.

- Ensure that the duct surface is reinforced, if necessary, to allow the unit to remain level and plumb.
- Ensure that the humidifier has adequate clearance to allow for the removal and replacement of the evaporator pad.
- When installing the humidifier in an attic or above a ceiling, a drain tray must be installed under the unit as a precautionary measure to prevent water damage from occurring if a leak develops.
- The recommended humidistat range is 30-40% relative humidity. If condensation occurs on windows, the humidistat setting must be lowered to prevent condensation damage.
- DO NOT install the humidifier where freezing temperatures may occur.
- DO NOT install the humidifier where it interferes with the furnace access panels.
- DO NOT install the humidifier close to a flue pipe. Intense heat may damage the humidifier.
- DO NOT mount the humidifier in the jacket of a cased coil. It is preferable to mount the humidifier immediately downstream of the cased coil, if present. Ensure that the humidifier does not interfere with the coil ends.
- DO NOT mount the humidifier in a furnace jacket.
- DO NOT install on gravity hot air systems.
- DO NOT connect a hot water supply to ComfortBreeze humidifiers that are equipped with water saving controls. (Model CB100S with ComfortSmart Technology).

### ⚠ IMPORTANT

The unit must be installed so that interconnection can be made to the source of electrical supply without the use of an extension cord.

1. Tape the mounting template to the duct so that it is flat and the top edge is level.
2. Carefully remove the center of the template by tearing along the perforated lines. Use a marker to trace on the duct along the cutout opening.

### ⚠ WARNING

Electrical power to the furnace must be disconnected before proceeding. Serious injury or death may result.

3. Drill the holes marked on the template. Remove the template from the duct and carefully cut the duct along the outside edge of the rectangle that was traced by the marker. Remove any burrs from the cut edge of the sheet metal taking care not to injure yourself.

4. Apply the gasket material found in the accessory bag to the duct around the rectangular cutout.
5. Lift the humidifier base into the rectangular opening so that the plastic tabs engage the lower edge of the rectangular opening. The tabs should be on the inside of the duct. Tilt the upper edge of the humidifier against the duct so that the mounting holes line up with the drilled holes on the duct. Secure the humidifier with two #8 X 3/4" self-drilling-sheet metal screws from the accessory bag.
6. Refer to the section regarding pad replacement on page 8. Complete that section before proceeding to ensure that the internal components of the humidifier are properly aligned/installed as they may have become misaligned during shipment. Failure to complete this task may result in faulty operation or leaks.
7. Ensure that the humidifier is level and plumb before proceeding.

### 4.3 Plumbing

1. Install a saddle valve and strainer (not provided) on the nearest cold water supply pipe. (See the instructions that accompany the saddle valve for additional details).
2. After the saddle valve and strainer are installed but before inserting the line into the humidifier supply fitting, turn the saddle valve to the open position and discharge the water into a bucket or pan. This will allow the water to flush any debris that may have accumulated in the line during the installation process. Once this is complete, close the saddle valve.
3. Attach the line to the humidifier by simply pushing the line into the push-to-lock fitting and pulling back slightly to seat the line. If it becomes necessary to remove the line, press on the release ring around where the line goes into the fitting to release the line and pull it out. See Figure 5 for plumbing diagram.
4. Connect the drain hose to the drain connection fitting and run this to an open, gravity drain. The end of this line must not be submerged in water or be trapped.
5. Turn on the saddle valve.
6. Ensure that no water is leaking from any of the fittings before proceeding.




Figure 5

### 4.4 Electrical

#### ⚠ CAUTION

This humidifier should be installed by a qualified service person only in accordance with the Nation Electric Code, ANSI/NFPA 70 and the Rules of the Canadian Electric Code, Part I, C22.1. Do not connect the unit to the power source until the installation is complete. A thorough checkout of the unit installation should be completed before operating the unit. Failure to follow these directions may void the manufacturer's original warranty.

The ComfortBreeze CB100/CB100S humidifier requires a 120 VAC source of electrical power. The unit is equipped with a line-cord so that this power source may be connected easily. Before proceeding, ensure that interconnection of the 120 VAC power may be accomplished without the use of an extension cord. In order to access the wiring compartment remove the screw as shown in Figure 6. Once the screw is removed, the door may be opened as shown in Figure 7.




Figure 6




Figure 7

**4.4.1 Wiring Model CB100 (without water saving controls)**

Wiring the high voltage portion of the unit:  
 Plug line cord into a source of 120 VAC electrical power. Provide means of overload protection as required.




Figure 8

Wiring the low voltage portion of the unit:  
 Refer to Figure 8. Air proving switch (not provided) is optional.

**4.4.2 Wiring Model CB100S (ComfortSmart equipped model)**

The CB100S is equipped with a circuit board that controls how the fan and water valve are powered. Figure 9 shows the main parts of the board. The wiring diagram is shown in figure 10. Refer to the wiring notes shown after Figure 10 for board wiring/control configurations that explain how to set the board based upon the type of system it is being installed on. These recommendations will provide the best performance and water savings.




Figure 9

Wiring the high voltage portion of the unit:  
 Plug line cord into a source of 120 VAC electrical power. Provide means of overload protection as required.




Figure 10

Wiring the low voltage portion of the unit:  
 The source of 24 VAC (low voltage) comes from the HVAC system terminals. The typical terminal designators are used, such as R, C, G, W, etc. The following list identifies the low voltage terminals and their respective connection.

- R = 24 VAC from the HVAC system
- C = 24 VAC common from the HVAC system
- Hr = 24 VAC output for powering the electronic humidistat (if equipped)
- Hc = 24 VAC common for the electronic humidistat (if equipped)
- H = Humidistat input (must be 24 VAC)
- W/G = Input from HVAC system. This is used when the humidifier is used with warm air furnaces. See DIP switch settings in section 5.
- AP1/AP2 = Air proving switch is connected here. Do not apply voltage.
- Go = 24 VAC output may be used to energize a relay or connected back to the thermostat "G" terminal to turn on the HVAC fan. Thermostat functionality may vary and affect the operation of this output.

Wiring Notes (CB100S only):

When installing the CB100S on a furnace system, the humidifier may operate only when there is a call-for-heat OR the humidifier may be configured to start the HVAC blower whenever there is a call-for-humidity.

Single Stage Furnace: Humidifier operates upon call-for-humidity only during a call-for-heat.

- DIP Switch #3: On

- DIP Switch #4: Off
- Air Proving Switch: Recommended but not required.
- Go Terminal: No Connection
- W/G Terminal: No Connection

Multi Stage/Modulating Furnace: Humidifier operates upon call-for-humidity only during a call-for-heat.

- DIP Switch #3: Off
- DIP Switch #4: Off
- Air Proving Switch: Required
- Go Terminal: No Connection
- W/G Terminal: No Connection

Single or Multi Stage Furnace: Humidifier operates upon a call-for-humidity and will start the HVAC blower.

- DIP Switch #3: Off
- DIP Switch #4: On
- Air Proving Switch: Recommended but not required.
- Go Terminal: Connected to System "G"
- W/G Terminal: Connected to System "W"

Although the capacity of the humidifier may be reduced by more than 40%, the CB100S may be installed on a heat pump system and configured to operate only when there is a call-for-heat OR the humidifier may be configured to start the HVAC blower whenever there is a call-for-humidity.

Heat Pump System: Humidifier operates upon call-for-humidity only during a call-for-heat.

- DIP Switch #3: Off
- DIP Switch #4: Off
- Air Proving Switch: Required
- Go Terminal: No Connection
- W/G Terminal: No Connection

Heat Pump System: Humidifier operates upon a call-for-humidity and will start the HVAC blower.

- DIP Switch #3: Off
- DIP Switch #4: On
- Air Proving Switch: Recommended but not required.
- Go Terminal: Connected to System "G"
- W/G Terminal: No Connection

## 5. Operation

Once the CB100/CB100S is installed and ready to be started, the humidistat and DIP switches on the control board within the humidifier unit must be configured. The CB100 without the ComfortSmart controls does not have any DIP switches to configure. You may skip to the Preliminary Checkout and Start-up Sequence.

DIP Switches/Settings:

- DIP #1 = Bypass or Motorized (Factory Set)
- DIP #2 = High Capacity/Low Capacity - This is factory set to High Capacity. If you determine that the humidifier is too large for the load, you may change the DIP switch position to ON. It is not necessary in most cases.
- DIP #3 = Temperature Check - If you are installing this humidifier on a system that will have duct temperatures regularly below 100°F, set this DIP switch to the OFF position. Typical furnace bonnet temperature is nominally

120°F.

- DIP #4 = Furnace Runs Fan/Humidifier Runs Fan - In most systems the HVAC system operates the main blower. The CB100S has a 24VAC output that may be used to start the main blower if you would like to be able to get some humidification while the furnace is off.
- DIP #5 = Temperature Override - This DIP switch is factory set to OFF. In the event of a T1 thermistor failure, this switch may be set to ON. This will allow the humidifier to operate temporarily with a single thermistor until a replacement is acquired.

### 5.1 Preliminary Checkout and Start-up Sequence

1. Check that unit drain plumbing is properly connected and drained.
2. Ensure that the supply plumbing is installed properly.
3. Open cold water supply and insure water is reaching the unit. Incoming water line should be filtered.
4. Ensure that the unit's line cord is plugged into an appropriate power source.
5. With the unit powered and the humidistat has a "call for humidity", the indicator LED (if equipped) will illuminate Green and the unit will begin operation.
6. If at any point the indicator LED illuminates red or blinks red/green alternating, a fault has been detected; service will be required and the fault must be reset. Refer to the Maintenance & Troubleshooting section.
7. Refer to the humidistat manual for "call for humidity" percentage settings.

### 5.2 Starting/Stopping the unit

In order to start and stop the unit you must only raise or lower the humidistat setting to a point at which the contacts are closed or open. When the humidistat contacts are closed, the unit will start. When the humidistat contacts are open, the unit will stop. Unplugging the line cord may not remove all sources of power to the unit.

## 6. Maintenance & Troubleshooting

### DANGER - RISK OF ELECTRIC SHOCK

Before cleaning, servicing, or parts replacement, the unit must be disconnected from all sources of electricity.

### 6.1 Pad Replacement

It will become necessary to replace the pad inside your Comfort-Breeze CB-100/CB100S humidifier as time goes on. A solid red LED Service indicator light may light up. This will tell you that it is time to service your humidifier. Please refer the following procedure.

1. Adjust Humidistat to the lowest setting to ensure that there is no call for humidity.
2. Unplug the humidifier in order to remove power before servicing the unit.
3. Close the water supply valve so that no water may flow to the humidifier during servicing.
4. Remove the screw that secures the wiring access cover.



See Figure 11.

5. Open the access cover and remove the screw on the right side of the opening that holds the motor dome to the base. See Figure 12.
6. With the screws removed, unplug the wiring from the motor to the circuit board (if equipped) or disconnect the 3 wire connector.
7. Lift the entire dome from the base of the unit by pulling the bottom of the dome away from the base and then lifting it off of the base. See Figure 13. If you disconnected the motor leads correctly, the motor dome should be free from the base and you can remove it completely. Do not hang the dome from the motor wires as damage can result.
8. To remove the evaporator pad, push the retaining clips and pull the top pad retainer out from the base. The retainer and pad will come out together. The drain pan stays inside the unit. See Figure 14.
9. Reassemble the humidifier.
10. If required, reset the service timer (RED LED) by pressing the reset button on the circuit board (if equipped) for three seconds. CB100S units with ComfortSmart Technology include a circuit board.




Figure 11




Figure 12




Figure 13




Figure 14

## 6.2 Control Board Faults & Reset

Faults are indicated by a red and green flashing LED located on the base of the unit in the lower left corner. (See figure XX above). There is a reset button on the control board that will reset the unit in the event of a fault. Use the fault list below and the troubleshooting chart to diagnose the fault and correct any issues that may be present.

When the LED is glowing solid green, the unit is humidifying and operating normally. The following list describes the faults that may occur and will be displayed by the LED's.

1. Rapid Red Blink = Terminals AP1 & AP2 for the air proving switch did not close. The unit will not operate until airflow is present.
2. Slow Red Blink = Once the solenoid valve is energized and humidification has begun, the controls must see a change in temperature or the unit will not be allowed to operate.
3. Alternating Red/Green Blink = One of the thermistors has failed.
  - If T1 has failed the LED will blink Green/Red/Red with a

two second delay. The unit will not operate in this condition unless DIP switch #5 is turned ON and the reset button is pressed.

- If T2 has failed the LED with blink Green/Green/Red with a two second delay. The unit will not operate in this condition unless the T1 thermistor is relocated to act as T2 and DIP switch #5 is turned ON. Using the override DIP switch is only recommended as a temporary solution until the failed thermistor can be replaced.
4. Solid Red LED = This functions to remind the homeowner to replace the evaporator pad. The unit will continue to operate and the LED may be cleared by pressing the reset button on the control board.

### 6.3 Motor Replacement

1. Follow steps 1-7 in the pad replacement section in order to separate the dome from the unit base.
2. Insert a flat-head screwdriver into the motor cover as shown in Figure 15. Tilt the screwdriver up as shown in Figure 16. This will release the motor cover and allow you to slide it off of the humidifier dome.
3. If you have a circuit board equipped unit (CB100S), unplug the motor cable from the circuit board. If you have a unit not equipped with a circuit board, unplug the white connector to free the motor leads from the relay board. The motor/dome will now be free from the base of the humidifier.
4. With the motor cover removed, as described in step 2, disconnect the quick-connects from the black and white wires. Also, remove the ground terminal from the motor by removing the ground screw.
5. Using an allen wrench, loosen the setscrew on the fan impeller to remove it from the motor shaft.
6. Using a nutdriver, remove the four nuts that secure the motor to the dome and remove the motor. Take care not to misplace the nuts, washers, & grommets. These will be used to mount the new motor.
7. Install the new motor to the dome using the nuts, washers, & grommets that you removed from the old motor. Refer to Figure 17 to see installation order.
8. With the new motor mounted to the dome, connect the ground wire to the motor and reconnect the quick-connect terminals on the black and white wires.




Figure 15




Figure 16

9. Replace the motor cover by sliding it onto the dome until it bottoms out. Place the dome back on the base and secure it with the screw removed previously. Refer to Figure 13.
10. Reconnect the motor cable that was disconnected as described in step 3.
11. Close the access door on the dome and replace the screw. Refer to Figure 12.

# Installation, Operation, & Maintenance Manual

## 6.3 Troubleshooting Chart CB100S (ComfortSmart) units only

Problem/Symptom	Probable Cause	Corrective Action
Power is applied and the LED does not illuminate.	No issue.	The LED does not illuminate unless the humidistat terminals are closed.
Humidistat contacts are closed but the unit will not operate.	System Calibration in progress.	Wait 2 minutes for the unit to begin operating.
	Solenoid Valve is not operating	Ensure that there is power supplied to the valve. Check control board output.
	Motor is not operating	Ensure that there is power supplied to the motor. Check control board output.
	Circuit Board has failed/fuse is blown	Replace circuit board.
Motor will not operate/turn.	Motor internal thermal protective device is open.	Remove power and allow motor to cool. Restart unit and ensure proper operation. If motor will not turn, replace motor.
	Motor has failed	Replace motor.
	Fan is stuck	Remove obstruction or replace fan/motor as necessary.
LED is glowing solid RED.	Service Timer has expired	Replace the humidifier pad and reset the LED. See page 8.
LED displays a rapid red blink.	Air proving switch did not close allowing the unit to start. Unit will not operate if airflow is not present.	Ensure that the fan is operating and reset the control board by pressing the reset button for 3 seconds.
LED displays a slow red blink.	No temperature change measured by thermistors.	Ensure thermistors are connected.
		Check water supply.
		Verify that the evaporator pad is getting wet.
LED displays an alternating red/green blink pattern.	Thermistor failure.	See page 9.




Figure 17




Figure 18




Figure 19

## Installation, Operation, & Maintenance Manual

265713-002 / CB-100 w/o circuit board	265713-001 / CB-100S w/ ComfortSMART Controls	ITEM	TRION P/N	DESCRIPTION
1	1	1	266372-001	SOLENOID VALVE, 24V, W/ CONNECTOR
1	-	2	G-217	FLUID RESTRICTOR (NOT SHOWN)
1	1	3	G-110	BLADE - FAN
-	1	4	G-128	FLUID RESTRICTOR
1	-	5	63667	TRANSFORMER - 120V-24V (NOT SHOWN)
1	1	6	265455-001	COMFORTBREEZE DRAIN TRAY
1	1	7	265456-001	COMFORTBREEZE FILTER RETAINER
-	1	8	265457-001	ASS'Y-DISTRIBUTION TUBE 18 HOLE
1	-	9	265457-002	ASS'Y-DISTRIBUTION TUBE 6 HOLE
1	1	10	265460-001	COMFORTBREEZE-SHROUD
1	1	11	266371-001	COMFORTBREEZE, MOTOR MAIN DOME
1	1	12	265462-001	COMFORTBREEZE MOTOR CAP
1	1	13	265463-001	COMFORTBREEZE DOME ACCESS DOOR
1	1	14	265470-001	PAD - EVAPORATOR
1	1	15	265471-001P	PAINT - BRACKET,SOLENOID VALVE
2	2	16	265698-001	PNEUMATIC PUSH-TO-CONNECT FITTING
1	1	17	153296-007	TUBING, 1/4" O.D. x 15" LG
-	1	18	266370-001	CONTROL BOARD, CB 100-S
1	-	19	265800-001	BOARD WITH RELAY, PLATE
-	2	20	266180-001	THERMISTOR ASSEMBLY, APPROX. 9"
-	1	21	265628-001	POWER CORD, 6'
1	1	22	265807-001	MOTOR ASS'Y
-	1	23	265846-001	WIRING HARNESS ASSY, CB100S (NOT SHOWN)
1	-	24	265846-003	WIRING HARNESS ASSY, CB100 (NOT SHOWN)
1	-	25	265847-001	POWER CORD ASS'Y
2	-	26	265849-001	MOTORIZED RELAY/TERM. WIRE (NOT SHOWN)
-	1	27	265160-002	HUMIDISTAT, ELECTRONIC (NOT SHOWN)
1	-	28	265160-001	HUMIDISTAT, MECHANICAL (NOT SHOWN)
1	1	29	266257-001	MAIN BASE CB100



**TRION<sup>®</sup>**  
Air Purification Systems

---

Trion<sup>®</sup>

101 McNeill Rd. | Sanford, NC 27330

P: 800.884.0002 | F: 800.458.2379 | [www.trioniaq.com](http://www.trioniaq.com) | [customerservice@trioniaq.com](mailto:customerservice@trioniaq.com)

---