

- Turn off power.
- Attach chain to fixture. Fixture loop has one chain link factory installed.
- Chain has one locking link at each end. Unscrew coupling on locking link and slip over link attached to loop. Screw coupling closed.
- Attach chain (with fixture connected) to bottom of screw collar loop following the same procedure as in step 1.

5) Weave electrical wire, ground wire and safety cable through chain links no more than 3 inches apart.

6) Pass electrical wire ground wire and safety cable through threaded ring (N) then canopy (M) onto chain (W)

7) Pass safety cable through loop (L) and into outlet box.

8) In area above outlet box wrap cable around one of the 2 x 4's erected in section 1 and pull cable taut..

9) Secure cable with (2) clamps provided.

**NOTE: Cable is not to be used as the only means of fixture support. Please follow independent mounting instructions completely.**

10) Connect fixture ground wire and ground wire attached to threaded rod (B or P) to outlet box ground wire with wire connector (not provided).

11) Make wire connections (connectors not provided). Reference chart below for correct connections and wire accordingly.

Connector Black or: Red Supply Wire to:	Connect Black	Wire Supply Wire to: White
Black		*
*Parallel cord (round & smooth)	*	Parallel cord (square & ridged)
Clear, Brown, Gold or Black without tracer	Clear, Brown, Gold or Black	
Insulated wire (other than green) with copper conductor	Insulated wire (other than green) with silver conductor	

*Note: When parallel wires (SP1 & SP2) are used, the neutral wire is spliced in or joined and the other wire will be round in shape or smooth (see illus.)*

12) Raise canopy (M) to ceiling.

13) Secure canopy (M) in place by screwing threaded ring (N) onto screw collar loop (L)

- Apague el suministro de potencia.
- Una la cadena (W) al artefacto. La argolla del artefacto tiene un eslabón de cadena instalado acoplamiento en el eslabón de cierre y deslícelo sobre el eslabón unido a la argolla. Atornille el eslabón para cierre. La cadena tiene un estabón de cierre (X) en cada extremo. Desatornille el eslabón de separación.
- Deslice el anillo roscado (N), luego el escudete (M) en la cadena (W).
- Una la cadena (con el artefacto conectado) a la parte inferior de la argolla con rosca (L), siguiendo el mismo procedimiento que en el paso 1.
- Intercala el alambre de corriente eléctrica y el de conexión a tierra por los eslabones a una distancia de separación no mayor a 3 pulgadas (7.6 cm).
- Pase el alambre de conexión a la corriente y el de conexión a tierra a través del anillo roscado (N), el escudete (M), la varilla roscada (B) dentro de la argolla con rosca (L) y dentro de la caja de salida.
- Fije el cable de soporte a través del orificio (Vea la sección 1.)
- En la zona arriba de la caja de salida haga entreda el cable alrededor de una de las vigas de 2 x 4's instaladas en la sección 1 y jale el cable tensionándolo.
- Fije el cable con dos (2) abrazaderas mismas que se proporcionan.

**NOTA: No deberá usar el cable como único medio de soporte del artefacto. Por favor siga las instrucciones de montaje independiente por completo.**

- Conecte el alambre de conexión a tierra de la varilla roscada (B), al alambre de tierra de la caja de salida (P) y la conexión a tierra del artefacto (vea la ilustración). Nunca conecte el alambre de tierra a los alambres blanco o negro del suministro de corriente.
- Haga las conexiones de los alambres (no se suministran los conectores). Referirse a la tabla de abajo para realizar las conexiones correctas de los cables.

Conectar el alambre de: suministro negro o rojo al	Conectar el alambre de: suministro blanco al
Negro	Blanco
*Cordon paralelo (redondo y liso)	*Cordon paralelo (cuadrado y estriado)
Claro, marrón, amarillo o negro sin hebra identificadora	Claro, marrón, amarillo o negro con hebra identificadora
Alambre aislado (diferente del color del conductor de cobre)	Alambre aislado (diferente del color del conductor de plata)

*\*Nota: Cuando se utiliza alambre paralelo (SP1 y SP2), el alambre neutro es de forma cuadrada o estriada y el otro alambre será de forma redonda o lisa. (Vea la ilustración).*

- Suba el escudete (M) hasta el techo.


- Fije el escudete (M) en su lugar atornillando el anillo roscado (N) en la argolla con rosca (L).

### 3

**NOTE:** NEC CODE (314.24) requires that ceiling outlet boxes in the United States support up to 100 lbs. This fixture exceeds 50 lbs. and must be installed using an outlet box approved for up to 100 lbs. or independently of the existing outlet box. Installation hardware and instructions are provided for both.

#### MOUNTING TO A 100 lb. MAX. APPROVED OUTLET BOX

- Support cable from fixture (see sec. 3) must pass through outlet box. Drill 3/16" diameter hole in outlet box if no other holes are available.
- Screw threaded rod (B) from parts bag into pipe coupling (A) until threaded rod is flush with top of pipe coupling. Secure in place by tightening allen head screw (C) with provided wrench.
- Pass threaded pipe (B) through mounting strap (D).
- Screw hexnut (H) onto threaded rod (B).
- Slip ground lug (F) and lockwasher (J) onto threaded rod (B).
- Thread screw collar loop (L) onto threaded rod (B) until threaded rod is flush with lower side of screw collar loop.
- Secure screw collar loop (L) in place by tightening hexnut (H) down against groundlug (F), lockwasher (J) and screw collar loop.
- Assemble mounting strap (D) and assembled parts to outlet box using screws provided with outlet box.
- Tight fit canopy (M) over screw collar loop. Approximately one half of the screw collar loop exterior threads should be exposed below canopy. To increase length of assembly loosen hexnut (H) and unscrew screw collar loop no more than two complete turns. To shorten, loosen allen head screw (C). Screw threaded pipe into coupling until desired height is met.
- After desired position is found, remove canopy and tighten allen head screw (C) and anti-rotational screw located next to center hole inside mounting strap (D).





**NOTA: EL CÓDIGO ELÉCTRICO NACIONAL (NEC, por sus siglas en inglés) (314.24) requiere que las cajas de salida para techo que se utilizan en los Estados Unidos soporten una carga de hasta 50 lb (22.7 kg). Este artefacto tiene un peso superior a 50 lb, por lo tanto debe instalarse usando una caja de salida que esté apropiada para usarse con cargas de hasta 100 lb (45.4 kg) o independientemente de la la caja de salida existente. A continuación se le proporcionan el equipo e instrucciones de instalación para las diferentes cajas de salida.**

#### MONTAJE A UNA CAJA DE SALIDA APROBADA PARA UN PESO MÁXIMO DE 100lb (45.4 kg)

- El cable de apoyo del artefacto (vea la Sección 3) debe pasar a través de la caja de conexiones. Perfore un agujero de 3/16" de diámetro en la caja de conexiones si no tiene otros agujeros disponibles.
- Atornille la varilla roscada (B) que se suministra en la bolsa de las partes, en el cople para tubo (A) hasta que la varilla esté al ras de la parte superior del cople. Asegúrela apretando el tornillo de cabeza allen (C) con las llaves que se le proporcionan para este fin.
- Pase la varilla roscada (B) por la barra o soporte de montaje (D).
- Atornille la tuerca hexagonal (H) en la varilla roscada (B).
- Deslice la rondana plana con el cable para tierra (F) y la rondana de seguridad (J) en la varilla roscada (B).
- Atornille la argolla con rosca en la varilla roscada (B) hasta que esté la varilla al ras del orificio que se encuentra en la parte inferior de la argolla con rosca.
- Asigure la argolla con rosca (L) en su lugar apretando la tuerca hexagonal (H) presionando contra la rondana plana con el cable para tierra (F), la rondana de seguridad (J) y la argolla con rosca.
- Ensamble la barra de montaje (D) y las partes ensambladas a la caja de salida usando los tornillos que se proporcionan con la caja.
- Haga la prueba de ajuste colocando el escudete de techo (M) sobre la argolla con rosca. Aproximadamente la mitad de las roscas exteriores de la argolla deberán estar expuestas por debajo del escudete. Para alargar el ensamble, afloje la tuerca hexagonal (H) y gire para destornillar la argolla con rosca, no más de dos vueltas completas. Para acortar, afloje el tornillo de cabeza allen (C). Atornille la varilla roscada en el cople hasta alcanzar la altura deseada.
- Una vez que se tiene la posición deseada, quite el escudete y apriete el tornillo de cabeza allen (C) y el tornillo contra la rotación localizado junto al orificio central al interior de la barra de montaje (D).
- Fije el escudete (M) en su lugar atornillando el anillo roscado (N) en la argolla con rosca (L).

### 1A




## MOUNTING TO A STANDARD OUTLET BOX

**1B**

**MEANS OF SUPPORT MUST BE ERECTED ABOVE OUTLET BOX. BELOW IS ONE SUGGESTED METHOD.**

- 1) Screw threaded rod (P) from parts bag into pipe coupling (A) until threaded pipe is flush with top of pipe coupling. Secure in place by tightening allen head screw (C) with provided wrench.
- 2) Slip mounting strap (D) over provided 1/2-13UNC threaded rod (P).
- 3) Remove knockout in top of outlet box.
- 4) Support cable from fixture (see sec. 3) must pass through outlet box.
- 5) Drill 3/16" diameter hole in outlet box if no other holes are available.
- 6) Lay a 2x4 across ceiling joist on either side of the threaded rod (P).
- 7) Secure 2x4's in place by toe-nailing or other means.
- 8) Screw finial (H) onto threaded rod (P).
- 9) Slip ground lug (F) and lockwasher (J) onto threaded rod (P).
- 10) Thread screw collar loop (L) onto threaded rod (P) until threaded pipe is flush with hole on lower side of screw collar loop.
- 11) Secure screw collar loop (L) in place by tightening hexnut (H) down against ground lug (F), lockwasher (J) and screw collar loop.
- 12) Temporarily slip canopy (M) over screw collar loop (L). Approximately one half of the screw collar loop exterior threads should be exposed below canopy.
- 13) Temporarily screw threaded ring (N) onto screw collar loop (L).
- 14) In area above outlet box pull up on threaded rod (P) until canopy is snug against ceiling.
- 15) Slide mounting strap (D) down threaded rod (P) until pipe coupling is snug against mounting strap (D) with provided allen wrench.
- NOTE:** Mounting strap (D) must be secured to prevent rotation.
- 16) Remove threaded ring (N) and canopy (M).
- 17) Tighten allen head screw (C).
- 18) Secure mounting strap (D) in place by laying diagonally across both 2x4's and driving two #10 x 1" sheet metal or equivalent screws (not provided) through holes at ends of mounting strap. Tighten anti-rotational hex screw located next to center hole inside mounting strap (D) with provided allen wrench.
- 19) Retire the anillo rosado (N) and el escudete (M).



### LOS ADITAMENTOS DE SOPORTE DEBEN INSTALARSE SOBRE LA CAJA DE SALIDA. A CONTINUACIÓN SE SUGIERE UN MÉTODO DE INSTALACIÓN

- 1) Atornille la varilla rosada (P) que se suministra en la bolsa de las partes, en el cope para tubo (A) hasta que el tubo rosado esté al ras de la parte superior del cope. Asegurelo en su lugar apretando el tornillo de cabeza allen (C) con la llave que se proporciona para tal propósito.
- 2) Deslice la barra de montaje (D) sobre la varilla rosada (P).
- 3) Retire el agujero ojero localizado arriba de la caja de salida. El cable de apoyo del artefacto (vea la Sección 3) debe pasar a través de la caja de conexiones. Perfore un agujero de 3/16" de diámetro en la caja de conexiones si no tiene otros agujeros disponibles.
- 4) Pase la varilla rosada (P) por arriba de la caja de salida a través del orificio central de la caja de salida.
- 5) Coloque una viga de techo de 2 x 4' a cada lado de la varilla rosada (P).
- 6) File las vigas con clavos colocados oblicuamente o por otros medios de fijación.
- 7) Atornille la tuerca hexagonal (H) en la varilla rosada (P).
- 8) Deslice temporalmente el escudete (M) sobre la argolla con rosca (L). Aproximadamente la mitad de las roscas exteriores de la argolla deberán estar expuestas por debajo del escudete.
- 9) Deslice la rondaica plana con el cable para tierra (F) y la rondana de seguridad (J) en la varilla rosada (P).
- 10) Atornille la argolla con rosca (L) en la varilla rosada (P) hasta que el tubo rosado esté al ras del orificio de la argolla rosada.
- 11) Asegure en su lugar la argolla con rosca (L) apretando la tuerca hexagonal (H) contra la rondana plana con el cable de tierra (F), la rondana de seguridad (J) y la argolla con rosca.
- 12) Deslice temporalmente el escudete (M) sobre la argolla con rosca (L). Aproximadamente la mitad de las roscas exteriores de la argolla deberán estar expuestas por debajo del escudete.
- 13) Atornille temporalmente el anillo rosado (N) en la argolla con rosca (L).
- 14) En el área arriba de la caja de salida, jale hacia arriba sobre la varilla rosada (P) hasta que el escudete tope contra el techo.
- 15) Introduzca la barra de montaje (D) en la varilla rosada y contra la parte superior de las vigas de 2 x 4'.
- 16) Atornille el cope para tubo (A) hacia abajo de la varilla rosada (P) hasta que el cope tope contra la barra de montaje (D) y que el escudete (M) tope contra el techo.
- 17) Apriete el tornillo de cabeza allen (C).
- 18) FILE la barra de montaje (D) en su lugar dejando en posición diagonal cruzada ambas vigas de 2 x 4' llevando dos placas metálicas de # 10 x 1" o tornillos equivalentes (no suministrados) a través de los orificios en los extremos de la barra de montaje. Apriete con el tornillo hexagonal contra la rotación localizada junto al orificio central dentro de la barra de montaje (D) con las llaves allen que se proporcionan.
- NOTA.** La barra de montaje (D) debe fijarse para evitar que gire.
- 19) Retire el anillo rosado (N) y el escudete (M).



- 1) Screw threaded pipe into top of fixture body.
- 2) Slip top trim over threaded pipe.
- 3) Screw loop onto threaded pipe at top of fixture body.

**For ease in assembly, proceed to section 3. Remaining steps in fixture assembly can be completed easier with fixture hanging.**

### MONTAJE DEL ARTEFACTO

- 1) Atornille el tubo rosado al tope del cuerpo del artefacto.
- 2) Resbale la garnición superior encima del tubo rosado.
- 3) Atornille el lazo al tubo rosado en el tope del cuerpo del artefacto.
- 4) Resbale el tubo rosado arriba a través del agujero en el centro del cuerpo del artefacto.
- 5) Atornille el capuchón al extremo del tubo rosado que sobresale arriba a través del centro del artefacto.
- 6) Resbale las piezas de garnición encima del tubo rosado.
- 7) Tornille el capuchón al extremo del tubo rosado.
- 8) Resbale el vidrio encima de los casquillos.
- 9) Atornille en el anillo del casquillo para sujetar el vidrio en el lugar. (NO apriete excesivamente.)

- 18) Secure mounting strap (D) in place by laying diagonally across both 2x4's and driving two #10 x 1" sheet metal or equivalent screws (not provided) through holes at ends of mounting strap. Tighten anti-rotational hex screw located next to center hole inside mounting strap (D) with provided allen wrench.
- 19) Remove threaded ring (N) and canopy (M).



**2**

**FIXTURE ASSEMBLY**

- 1) Screw threaded pipe into top of fixture body.
- 2) Slip top trim over threaded pipe.
- 3) Screw loop onto threaded pipe at top of fixture body.

**Drill 3/16" diameter hole in outlet box if no other holes are available.**

**Approximately one half of the screw collar loop exterior threads should be exposed below canopy.**

**Threads should be exposed below canopy.**

**In area above outlet box pull up on threaded rod (P) until canopy is snug against ceiling.**

**Slide mounting strap (D) down threaded rod (P) until pipe coupling is snug against mounting strap (D) with provided allen wrench.**

**NOTE: Mounting strap (D) must be secured to prevent rotation.**

**Remove threaded ring (N) and canopy (M).**

**Tighten allen head screw (C).**

**Secure mounting strap (D) in place by laying diagonally across both 2x4's and driving two #10 x 1" sheet metal or equivalent screws (not provided) through holes at ends of mounting strap. Tighten anti-rotational hex screw located next to center hole inside mounting strap (D) with provided allen wrench.**

**Remove threaded ring (N) and canopy (M).**

**Temporarily screw threaded ring (N) onto screw collar loop (L).**

**In area above outlet box pull up on threaded rod (P) until canopy is snug against ceiling.**

**Slide mounting strap (D) down threaded rod (P) until pipe coupling is snug against mounting strap (D) with provided allen wrench.**

**NOTE: Mounting strap (D) must be secured to prevent rotation.**

**Remove threaded ring (N) and canopy (M).**

**Tighten allen head screw (C).**

**Secure mounting strap (D) in place by laying diagonally across both 2x4's and driving two #10 x 1" sheet metal or equivalent screws (not provided) through holes at ends of mounting strap. Tighten anti-rotational hex screw located next to center hole inside mounting strap (D) with provided allen wrench.**

**Remove threaded ring (N) and canopy (M).**

**Temporarily screw threaded ring (N) onto screw collar loop (L).**

**In area above outlet box pull up on threaded rod (P) until canopy is snug against ceiling.**

**Slide mounting strap (D) down threaded rod (P) until pipe coupling is snug against mounting strap (D) with provided allen wrench.**

**NOTE: Mounting strap (D) must be secured to prevent rotation.**

**Remove threaded ring (N) and canopy (M).**

**Tighten allen head screw (C).**

**Secure mounting strap (D) in place by laying diagonally across both 2x4's and driving two #10 x 1" sheet metal or equivalent screws (not provided) through holes at ends of mounting strap. Tighten anti-rotational hex screw located next to center hole inside mounting strap (D) with provided allen wrench.**

**Remove threaded ring (N) and canopy (M).**

**Temporarily screw threaded ring (N) onto screw collar loop (L).**

**In area above outlet box pull up on threaded rod (P) until canopy is snug against ceiling.**

**Slide mounting strap (D) down threaded rod (P) until pipe coupling is snug against mounting strap (D) with provided allen wrench.**

**NOTE: Mounting strap (D) must be secured to prevent rotation.**

**Remove threaded ring (N) and canopy (M).**

**Tighten allen head screw (C).**

**Secure mounting strap (D) in place by laying diagonally across both 2x4's and driving two #10 x 1" sheet metal or equivalent screws (not provided) through holes at ends of mounting strap. Tighten anti-rotational hex screw located next to center hole inside mounting strap (D) with provided allen wrench.**

**Remove threaded ring (N) and canopy (M).**

**Temporarily screw threaded ring (N) onto screw collar loop (L).**

**In area above outlet box pull up on threaded rod (P) until canopy is snug against ceiling.**

**Slide mounting strap (D) down threaded rod (P) until pipe coupling is snug against mounting strap (D) with provided allen wrench.**

**NOTE: Mounting strap (D) must be secured to prevent rotation.**

**Remove threaded ring (N) and canopy (M).**

**Tighten allen head screw (C).**

**Secure mounting strap (D) in place by laying diagonally across both 2x4's and driving two #10 x 1" sheet metal or equivalent screws (not provided) through holes at ends of mounting strap. Tighten anti-rotational hex screw located next to center hole inside mounting strap (D) with provided allen wrench.**

**Remove threaded ring (N) and canopy (M).**

**Temporarily screw threaded ring (N) onto screw collar loop (L).**

**In area above outlet box pull up on threaded rod (P) until canopy is snug against ceiling.**

**Slide mounting strap (D) down threaded rod (P) until pipe coupling is snug against mounting strap (D) with provided allen wrench.**

**NOTE: Mounting strap (D) must be secured to prevent rotation.**

**Remove threaded ring (N) and canopy (M).**

**Tighten allen head screw (C).**

**Secure mounting strap (D) in place by laying diagonally across both 2x4's and driving two #10 x 1" sheet metal or equivalent screws (not provided) through holes at ends of mounting strap. Tighten anti-rotational hex screw located next to center hole inside mounting strap (D) with provided allen wrench.**

**Remove threaded ring (N) and canopy (M).**

**Temporarily screw threaded ring (N) onto screw collar loop (L).**

**In area above outlet box pull up on threaded rod (P) until canopy is snug against ceiling.**

**Slide mounting strap (D) down threaded rod (P) until pipe coupling is snug against mounting strap (D) with provided allen wrench.**

**NOTE: Mounting strap (D) must be secured to prevent rotation.**

**Remove threaded ring (N) and canopy (M).**

**Tighten allen head screw (C).**

**Secure mounting strap (D) in place by laying diagonally across both 2x4's and driving two #10 x 1" sheet metal or equivalent screws (not provided) through holes at ends of mounting strap. Tighten anti-rotational hex screw located next to center hole inside mounting strap (D) with provided allen wrench.**

**Remove threaded ring (N) and canopy (M).**

**Temporarily screw threaded ring (N) onto screw collar loop (L).**

**In area above outlet box pull up on threaded rod (P) until canopy is snug against ceiling.**

**Slide mounting strap (D) down threaded rod (P) until pipe coupling is snug against mounting strap (D) with provided allen wrench.**

**NOTE: Mounting strap (D) must be secured to prevent rotation.**

**Remove threaded ring (N) and canopy (M).**

**Tighten allen head screw (C).**

**Secure mounting strap (D) in place by laying diagonally across both 2x4's and driving two #10 x 1" sheet metal or equivalent screws (not provided) through holes at ends of mounting strap. Tighten anti-rotational hex screw located next to center hole inside mounting strap (D) with provided allen wrench.**

**Remove threaded ring (N) and canopy (M).**

**Temporarily screw threaded ring (N) onto screw collar loop (L).**

**In area above outlet box pull up on threaded rod (P) until canopy is snug against ceiling.**

**Slide mounting strap (D) down threaded rod (P) until pipe coupling is snug against mounting strap (D) with provided allen wrench.**

**NOTE: Mounting strap (D) must be secured to prevent rotation.**

**Remove threaded ring (N) and canopy (M).**

**Tighten allen head screw (C).**

**Secure mounting strap (D) in place by laying diagonally across both 2x4's and driving two #10 x 1" sheet metal or equivalent screws (not provided) through holes at ends of mounting strap. Tighten anti-rotational hex screw located next to center hole inside mounting strap (D) with provided allen wrench.**

**Remove threaded ring (N) and canopy (M).**

**Temporarily screw threaded ring (N) onto screw collar loop (L).**

**In area above outlet box pull up on threaded rod (P) until canopy is snug against ceiling.**

**Slide mounting strap (D) down threaded rod (P) until pipe coupling is snug against mounting strap (D) with provided allen wrench.**

**NOTE: Mounting strap (D) must be secured to prevent rotation.**

**Remove threaded ring (N) and canopy (M).**

**Tighten allen head screw (C).**

**Secure mounting strap (D) in place by laying diagonally across both 2x4's and driving two #10 x 1" sheet metal or equivalent screws (not provided) through holes at ends of mounting strap. Tighten anti-rotational hex screw located next to center hole inside mounting strap (D) with provided allen wrench.**